



**ANNAPOLIS FIRE DEPARTMENT
FIRE MARSHAL'S OFFICE**



*145 Gorman Street, 3rd Floor
ANNAPOLIS, MARYLAND 21401
E-Mail: jdmuhitch@annapolis.gov
Phone: 410-260-2202 Fax: 410-260-2237*

PLAN REVIEW COMMENTS

DATE: 1 August 2019
TO: Bozzuto Homes, Inc.
PERMIT #: BLD 17-0274
ATTN: NFPA 101 & IBC Review
FROM: Capt. Muhitch
RE: 133 – 143 West St.

- Approved
- Disapproved
- Revisions Required
- Approved with comments

COMMENTS:

1. The plans were reviewed under NFPA 101, 2015 edition, and the IBC 2015 edition.
2. The City of Annapolis FMO will require “all” elevator lobby doors with hold opens to close on any general building alarm or any elevator lobby smoke detector activation.

Standard Comments:

3. All interior finishes shall be in accordance with Chapter 10 of NFPA 101 and Table 803.11 of the IBC.
 4. Fire alarm, fire sprinkler systems, and/or special suppression systems and items such as kitchen hood exhaust make-up air have not been reviewed under this submission. Separate permit submittals will be required for these systems.
 5. Emergency lighting, exit signs and fire extinguisher placement will be evaluated during the FMO inspections.
- If you have any questions, please contact Capt. Muhitch, at 410-260-2202.