



**ANNAPOLIS FIRE DEPARTMENT
FIRE MARSHAL'S OFFICE**



*145 Gorman Street, 3rd Floor
ANNAPOLIS, MARYLAND 21401
E-Mail: jdmuhitch@annapolis.gov
Phone: 410-260-2202 Fax: 410-260-2237*

PLAN REVIEW COMMENTS

DATE: 13 December 2018
TO: State Street Holdings
PERMIT #: BLD 18-0633
ATTN: NFPA 101 and IBC Review
FROM: Capt. Muhitch
RE: 1 Walton Ln.

- Approved
- Disapproved
- Revisions Required
- Approved with comments

COMMENTS:

1. The plans were reviewed under NFPA 101, 2015 edition and IBC, 2015 edition.

Standard Comments:

2. All interior finishes shall be in accordance with Chapter 10 of NFPA 101 and Table 803.11 of the IBC.
3. Fire alarm, fire sprinkler systems, and/or special suppression systems and items such as kitchen hood exhaust make-up air have not been reviewed under this submission. Separate permit submittals will be required for these systems.
4. Emergency lighting, exit signs and fire extinguisher placement will be evaluated during the FMO inspections.

If you have any questions, please contact Capt. Muhitch at 410-260-2202.