



**ANNAPOLIS FIRE DEPARTMENT
FIRE MARSHAL'S OFFICE**



*145 Gorman Street, 3rd Floor
ANNAPOLIS, MARYLAND 21401
E-Mail: bjzapata@annapolis.gov
Phone: 410-260-2202 Fax: 410-260-2237*

PLAN REVIEW COMMENTS

DATE: 30 March 2021
TO: Tank Systems Services, LLC
PERMIT #: BLD 21-0265
FROM: Capt. Zapata
RE: 2 Compromise Street (Fuel Tank and Piping Replacement)

Approved

Disapproved

Revisions Required

Approved with the comments

COMMENTS:

1. The plans were reviewed under NFPA 1 (2018), NFPA 30 (2018), NFPA 30A (2018) & NFPA 303 (2016).
2. Please provide architect and/or professional engineer seal and signature as appropriate on all drawings in accordance with the Charter and Code of the City of Annapolis section 17.05.070 item D.
3. Please provide product literature demonstrating the following items/systems are in compliance with NFPA 1 (2018) section 42.3.3, NFPA 30 (2018) chapters 21 & 23, and NFPA 30A (2018) section 4.3.2.
 - a. fuel storage tanks
 - b. fuel tank anchoring systems
 - c. tank bedding/backfill
 - d. surface/ground cover are appropriate for vehicle traffic and the above listed NFPA sections



ANNAPOLIS FIRE DEPARTMENT FIRE MARSHAL'S OFFICE

145 Gorman Street, 3rd Floor
ANNAPOLIS, MARYLAND 21401
E-Mail: bjzapata@annapolis.gov
Phone: 410-260-2202 Fax: 410-260-2237



4. Provide product literature for the piping systems demonstrating compliance with NFPA 1 (2018) section 42.4.
5. Verify fueling procedures and posted placards are in accordance with NFPA 1 (2018) section 28.1.4.2.7 and NFPA 303 (2016) chapter 8.
6. Verify the dispensing nozzles are in accordance with NFPA 1 (2018) section 42.5.6.4 and NFPA 303 (2016) section 8.4.10.
7. Verify Extra (High) Hazard fire extinguishers are provided on both sides of the fuel dispensing area in accordance with NFPA 1 (2018) section 28.1.2.1.1.1.2 and NFPA 10 (2017) chapter 5.
8. Coordinate all NFPA 30 (2018) chapter 21 operational procedures, inspections, and emergency and flood procedures with the FMO inspectors prior to installation.

If you have any questions, please contact Capt. Zapata at 410-260-2202.