



**ANNAPOLIS FIRE DEPARTMENT  
FIRE MARSHAL'S OFFICE**



145 Gorman Street, 3<sup>rd</sup> Floor  
ANNAPOLIS, MARYLAND 21401  
E-Mail: [bjzapata@annapolis.gov](mailto:bjzapata@annapolis.gov)  
Phone: 410-260-2202 Fax: 410-260-2237

**PLAN REVIEW COMMENTS**

**DATE:** 14 July 2021  
**TO:** Tank Systems Services, LLC  
**PERMIT #:** BLD 21-0265  
**FROM:** Capt. Zapata  
**RE:** 2 Compromise Street (Fuel Tank and Piping Replacement)

Approved

Disapproved

Revisions Required

Approved with the comments

**COMMENTS:**

1. The plans were reviewed under NFPA 1 (2018), NFPA 30 (2018), NFPA 30A (2018) & NFPA 303 (2016).
2. Prior to inspections, verify fueling procedures and posted placards with the FMO inspectors for compliance with NFPA 1 (2018) section 28.1.4.2.7 and NFPA 303 (2016) chapter 8. (The 2018 edition of NFPA 1 section 28.1.4.2.7 item (1)(f) additionally requires the note under "Procedures Before Fueling": **Remove all personnel from the boat except the person handling the fueling hose.**)
3. Coordinate all NFPA 30 (2018) chapter 21 operational procedures, inspections, and emergency and flood procedures with the FMO inspectors prior to installation.

If you have any questions, please contact Capt. Zapata at 410-260-2202.