



**ANNAPOLIS FIRE DEPARTMENT  
FIRE MARSHAL'S OFFICE**



145 Gorman Street, 3<sup>rd</sup> Floor  
ANNAPOLIS, MARYLAND 21401

E-Mail: [cfruth@annapolis.gov](mailto:cfruth@annapolis.gov)

Phone: 410-260-2202

Fax: 410-260-2237

**PLAN REVIEW COMMENTS**

**DATE:** 13 May 2022  
**TO:** Permits By Pinecrest  
**PERMIT #:** BLD 22-0227  
**FROM:** Chuck Ruth  
**RE:** 1410 Forest Dr.

Approved

Disapproved

Revisions Required

Approved with the comments

**COMMENTS:**

1. The plans were reviewed under NFPA 1 (2018) and NFPA 101 (2018).
2. Per conversations with Level One Architects, LLC the design may be modified to utilize a Type II kitchen hood system in lieu of a Type I. If a Type II is specified, please modify the MEP's accordingly and resubmit. If the Type I is preferred, please provide additional information with respect to the exhaust duct discharge on the exterior of the building. Items include but may not be limited to distance from property lines, air intakes, and operable windows or doors.

**Standard Comments (where applicable):**

3. All interior finishes shall be in accordance with Chapter 10 of NFPA 101 and Table 803.11 of the IBC.



**ANNAPOLIS FIRE DEPARTMENT  
FIRE MARSHAL'S OFFICE**

*145 Gorman Street, 3<sup>rd</sup> Floor  
ANNAPOLIS, MARYLAND 21401*

*E-Mail: cfruth@annapolis.gov*

Phone: 410-260-2202 Fax: 410-260-2237



4. Fire alarm, fire sprinkler system, and/or special suppression systems and items such as kitchen hood exhaust make-up air have not been reviewed under this submission. Separate permit submittals will be required for these systems if they require modifications.
5. Emergency lighting, exit signs and fire extinguisher placement will be evaluated during the FMO inspections.
6. The City of Annapolis FMO requires a 4", Storz connection (listed for fire protection service) on a 30 degree bend with a lockable cap for all Fire Department Connections.
7. Please note: the door hardware shall comply with NFPA 101 (2018) sections 7.2.1.5 & 7.2.1.5.10.2 and IBC section 1001.1.9.5.

If you have any questions, please contact Chuck Ruth at 410-260-2202.