



**ANNAPOLIS FIRE DEPARTMENT
FIRE MARSHAL'S OFFICE**



145 Gorman Street, 3rd Floor
ANNAPOLIS, MARYLAND 21401

E-Mail: cfruth@annapolis.gov

Phone: 410-260-2202

Fax: 410-260-2237

PLAN REVIEW COMMENTS

DATE: 26 September 2022
TO: Permits By Pinecrest
PERMIT #: BLD 22-0227
FROM: Chuck Ruth
RE: 1410 Forest Dr.

Approved

Disapproved

Revisions Required

Approved with the comments

COMMENTS:

1. The plans were reviewed under NFPA 1 (2018) and NFPA 101 (2018).

Standard Comments (where applicable):

2. All interior finishes shall be in accordance with Chapter 10 of NFPA 101 and Table 803.11 of the IBC.
3. Fire alarm, fire sprinkler system, and/or special suppression systems and items such as kitchen hood exhaust make-up air have not been reviewed under this submission. Separate permit submittals will be required for these systems if they require modifications.
4. Emergency lighting, exit signs and fire extinguisher placement will be evaluated during the FMO inspections.
5. The City of Annapolis FMO requires a 4", Storz connection (listed for fire protection service) on a 30 degree bend with a lockable cap for all Fire Department Connections.



**ANNAPOLIS FIRE DEPARTMENT
FIRE MARSHAL'S OFFICE**

*145 Gorman Street, 3rd Floor
ANNAPOLIS, MARYLAND 21401*

E-Mail: cfruth@annapolis.gov

Phone: 410-260-2202 Fax: 410-260-2237



6. Please note: the door hardware shall comply with NFPA 101 (2018) sections 7.2.1.5 & 7.2.1.5.10.2 and IBC section 1001.1.9.5.

If you have any questions, please contact Chuck Ruth at 410-260-2202.