

CITY OF ANNAPOLIS

ELECTRICAL PERMIT

THIS PERMIT MUST BE POSTED AND VISIBLE FROM STREET WITHIN 24 HOURS OF ISSUANCE.

WORK MUST COMMENCE WITHIN 90 DAYS.

NO CONSTRUCTION WORK OR MACHINERY SHALL START PRIOR TO 7:00 A.M. AND SHALL FINISH NO LATER THAN DUSK, AND THERE SHOULD BE NO OUTSIDE SUNDAY WORK UNLESS APPROVED OTHERWISE

ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE ADOPTED NATIONAL ELECTRICAL CODE WITH LOCAL AMENDMENTS AND THE ADOPTED NATIONAL ELECTRICAL SAFETY CODE

INSPECTOR: CLINTON C. PRATT

CALL FOR ALL REQUIRED INSPECTIONS (410) 260-2200

PERMIT CARD MUST REMAIN ON SITE AND POSTED UNTIL JOB IS FINALED

PERMIT NUMBER: ELE22-0319

RELATED BUILDING PERMIT: BLD21-0413

ISSUE DATE: 04/11/2022		EXPIRATION DATE: 12/10/2023	
JOB ADDRESS: 100 RIDGELY AVE UNIT D		W.M.S. or Work Order # 16758891	
CONTRACTOR: DESHAIES, RYAN	City License #: CON-2650	PHONE: (410) 280-3388	
OWNER: 100 RIDGELY AVE, LLC		PHONE: (443) 808-1491	

REMARKS: NEW SERVICE 200AMP SERVICE EQUIPMENT

(4/11/2022 9:20 AM TC)

200AMP SERVICE CONDUCTORS, 30 SWITCHES, 30 RECEPTACLES, 40 MEDIUM BASE FIXTURES, 2 PADDLE FANS, 2 BATHROOM EXHAUST FAN, 1 RANGEHOOD EXHAUST FAN, 6 SMOKE DETECTORS (120V), 1 CATV, 1/2HP GARBAGE DISPOSAL, 8KW OVEN, 1.4KW DISHWASHER, 5KW WATER HEATER, 30 AMP AIR CONDITIONER, 1 30AMP RECEPTACLES, 50AMP RECEPTACLES

TYPE	INSPECTOR SIGN	PASS	FAIL	DATE	COMMENTS
SLAB INSPECTION					
TRENCH INSPECTION					
WALL CLOSE IN					
CEILING CLOSE IN					
ROUGH IN					
TEMPORARY POWER					
DEMO INSPECTION					
SERVICE INSPECTION	<i>Clinton Pratt</i>	<i>A</i>		<i>6-28-22</i>	
MISC INSPECTION					