



**ANNAPOLIS FIRE DEPARTMENT
FIRE MARSHAL'S OFFICE**



*145 Gorman Street, 3rd Floor
ANNAPOLIS, MARYLAND 21401
E-Mail: cfruth@annapolis.gov
Phone: 410-260-2202 Fax: 410-260-2237*

PLAN REVIEW COMMENTS

DATE: 26 October 2021
TO: Absolute Fire Protection
PERMIT #: FIRE 21-0082
ATTN: NFPA 13 Submittal
FROM: Chuck Ruth
RE: 182 Duke of Gloucester St.

Approved

Disapproved

Revisions Required

Approved with comments

COMMENTS:

1. The plans were reviewed under NFPA 13, 2016 edition.
2. Coordinate FMO inspections for piping inspections, verification of insulation installation to allow omission of sprinklers and verification of insulation required to protect from freezing. Which is required before FMO approval to close-in piping.

If you have any questions, please contact Chuck Ruth, at 410-260-2202.