



City of Annapolis

Department of Neighborhood & Environmental Programs

160 Duke of Gloucester Street

Annapolis, MD 21401-2517



DNEP@annapolis.gov • 410-263-7946 • Fax 410-263-9158 • www.annapolis.gov

Deaf, hard of hearing or speech disability - use MD Relay or 711

Revision Submittals

This form must accompany all submittals of revised plans.

You are required to submit five copies (six if commercial) of both the original and revised plans.

Job location address 182 DUKE OF GLOUCESTER

Submitted by Absolute Fire Protection, Inc.

Phone (410)544-7771 Date 10/25/21

Attachments (please check one)

Permit #

Revisions to a permit currently being processed

Revisions to a permit already issued FIRE 21-0082 Issue date 6/7/21

Additional plans for permit currently being processed

Describe changes from original submission. Unless all pages have been revised, include page numbers containing revisions. Drawing changes should be "bubbled," highlighted or indicated in some way.

AS-BUILT drawings to include additional heads under the 2nd floor bulkheads, to show where a head will be added at the top of the basement stairwell. Also added ball drip valve for FDC and a low point drain valve on the inspector test drain.

Total cost of changes 0

Revisions requested by applicant

Revisions requested by City – Department/Employee Insp. JACOBELLI / CHUCK RUTH

Signature Jessica Wickman Date 10/29/21