



Annapolis Fire Department
Fire Marshal's Office
145 Gorman Street 3rd Floor
Annapolis, MD 21401
Phone: 410-260-2202
Fax: 410-260-2237

No.: 2022 00020
Date: 01/14/2022

System Test Report (Form #80)

SYSTEM TEST REPORT

Permit Number Fire21-0082
Date 01/14/2022
Time 10:09
Address 182 Duke of Gloucester Street
Business Name
--
Type of Test Hydrostatic Test
Firm/Organization Conducting Test
Firm/Organization Name Absolute
Representative(s) Conducting Test Alex
Representative Conducting Test Contact Number 4105447771
Representative Conducting Test Signature

--
Other Agencies Present
Company Name
Representative Name
Representative Signature

--
Hydrant Coefficient
Static Hydrant Location / Number
Static Pressure (Before Flow)
Residual Pressure (During Flow)
Flow Hydrant Location / Number
Flow Hydrant Pressure
Remarks

Water was turned off. Tampers were missing. Install tampers per plans

SIGNATURE

Result of Test Fail
Witnessed By Inspector D. Jacobelli FM38

NOT TO BE USED FOR ENGINEERING PURPOSES