

E&S Inspection Issues from January 14, 2022

GRD15-0026 – Annapolis Neck Road – Parkside Preserve

Please see inspection report (E & S Inspection Survey - 745 Annapolis Neck 2022-01-14.pdf) for more notes and pictures. The Following items need to be addressed:

1. Temporary stabilization in accordance with 26.17.01.07(B)(6)(f) needs corrective actions. Location: **Last Building pad beside the second trap far left corner of the site needs more seed and straw applied**
Date to be Completed: **Jan 19, 2022**
2. Stockpile Protection needs to be repaired. Location: **Stock pile far left corner beside the trap needs Rsf repaired**
Date to be Completed: **Jan 19, 2022**
3. Stabilized Construction Entrance needs maintenance.
Date to be Completed: **Jan 14, 2022**