



**ANNAPOLIS FIRE DEPARTMENT
FIRE MARSHAL'S OFFICE**



*145 Gorman Street, 3rd Floor
ANNAPOLIS, MARYLAND 21401
E-Mail: jbowes@annapolis.gov
Phone: 410-260-2202 Fax: 410-260-2237*

PLAN REVIEW COMMENTS

DATE: 10 October 2016
TO: Annapolis Public Library & Capt. Bowes
PERMIT #: SE 2016-007
ATTN: NFPA 1
FROM: Chuck Ruth
RE: 1410-1420 West St.

Approved

Disapproved

Revisions Required

Approved with comments

COMMENTS:

1. The plans were reviewed under NFPA 1, 2015 edition.
2. An NFPA 101 or IBC evaluation was not submitted with the site plan review package. Therefore exterior wall fire ratings, unprotected openings and the need to install a fire sprinkler system have not been evaluated at this time. Construction types, fire rated separations and unprotected openings will need to be addressed during the architectural review process to allow the omission of a fire sprinkler system and to adequately evaluate the construction types permitted by the International Building Code.

If you have any questions, please contact Chuck Ruth, at 443-677-5991